

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/258/FSCR/DFO/BELAGAVI/2026

Date : 21-07-2026

To,
The Principal,
Shri Shankarling Model School,
Chikkalgud, Hukkeri Taluk & Belagavi District.

Sir,

Sub: Issue of "**Fire Safety Compliance Report**" to Shri Shri Shankarling Institute of Rural Development's, Shri Shankarling Model School, Chikkalgud, Hukkeri Taluk & Belagavi District.

Ref:- C.No.08/FSCR/FSO/Hattaragi/2026 Date: 21-07-2026

*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of **Shri Shri Shankarling Institute of Rural Development's, Shri Shankarling Model School**, building consisting with Ground Floor & 1 Upper floor situated at **Chikkalgud Village, Hukkeri Taluk & Belagavi District** was inspected by Fire Station Officer Hattaragi on 21-07-2026 with respect to fire Prevention, Fire fighting and Evacuation measures to be complied in the above premises and the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height) GROUP-B Educational Buildings
NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Principal, Shri Shankarling Model School, Chikkalgud, Hukkeri Taluk & Belagavi District.
02	Name and Address of the Premises	Shri Shri Shankarling Institute of Rural Development's, Shri Shankarling Model School, Chikkalgud, Hukkeri Taluk & Belagavi District.
03.	Name and Address of the Building Owner	The President, Sri Shrikant B Hatanuri Sri Shankarling Institute of Rural Development's Tq-Hukkeri Dist-Belagavi,
04.	Number of Building	01
05.	Number of Floors	Ground and 01 Upper floor
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Class room-14, Principal Room cum Office-01, Comp Lab-01, Science Lab-01, Musical room-01 Staff room-01.
	1 st Floor	Class rooms-15, Library-01, Function Hall-01
07.	Height of the building	08.20 Mtr
08.	Site area	32,071.33 Sq Mtr Sqm
09.	Built-up area of each floor:-	
	Ground Floor	3644.01 Sq Mtr
	1 st Floor	3644.01 Sq Mtr

[Handwritten signature]
21/7/26

10.	Total Built-up area	7288.02 Sq Mtr
11.	Surrounding properties:-	
	East	NH-48 Service Road
	West	Agricultural Land
	North	Agricultural Land
	South	Agricultural Land
12.	Open Space all around the building	
	East	16.60 Mtr
	West	40.00 Mtr
	North	30.00 Mtr
	South	07.40 Mtr
13	U-DISE Number	29300702603
	Allowed Setbacks (open space) should be maintained free from further obstruction/construction.	

B.On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

SL.N (01)	Details (02)	Existing (03)	Recommendations (04)	
01.	Accessibility to the premises	The premise is accessible from 09.00 mtrs wide road on the Eastern side	Adequate	
02.	Number of Entrances	01 No. of Open Entrance & 04 Nos. Exits of 02.30 Mtr Wide gates with shutters	Adequate	
03.	Number of Staircase	No of staircase	04 all are equal measures	Adequate
		Width of the staircase	01.50Mtr	
		Width of threads	0.30 Mtr	
		Height of risers	0.15 Mtr	
		No of risers per flight	10	
		Height of the hand drill.	01.00 Mtr	
04.	Portable Extinguishers	13 No's. of 06 Kg Capacity ABC Fire Extinguishers has been Provided All the extinguishers suggested are BIS marking and are located at an easily accessible position without obstructing the normal passage	Complied	
05.	Escape routes	Direction in which the students have to move in the event of an emergency have been indicated in the corridor on each floor during evacuation.	Complied	
06.	Fire Order (Fire safety plans)	A notice board indicating the action to be taken by the employees in case of any emergency have been displayed along with the telephone numbers of Hattaragi Fire station i.e. 8310940091, 101, 112 and the telephone no's nearest ambulance services and police station.	Complied	

[Handwritten Signature]
21/11/18

07.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board is written in the English & Kannada both languages is displayed at inside the entry/exit of the each floor.	Complied
08.	Fire Siren	A fire siren has been installed in the premises to inform the students/ teachers in case of a fire emergency and evacuate the area.	Complied
09.	Nominate One Fire Nodal Officer	Sri Vinayak Malnayak Has been Nominated as School Fire Nodal Officer	Complied
10.	Fire Fighting Training	Two Persons have been undergone basic fire fighting training at Belagavi Sri Vinayak Malnayak Sri Jyotiba Kurude	At Least 40% of the Teaching and non teaching staff should be got trained in basic fire Fighting at R.A. Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre.
<u>Fire Precautionary Measures</u> <i>A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.</i> <i>B:- Accumulation of combustible waste in and around the premises should be avoided.</i> <i>C:- The Exit ways shall be always kept clear without any obstruction.</i> <i>D:- Liquefied petroleum gas should not be stored in the building.</i> <i>E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.</i> <i>F:- During the class hours the class room door shall not be locked from inside to out side.</i> <i>G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.</i>			

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Compliance Report" to Shri Shri Shankarling Institute of Rural Development's, Shri Shankarling Model School, Chikkalgud, Hukkeri Taluk & Belagavi District. As they have complied all the recommendations as per reference 1. The staff should get trained in the basic fire fighting at R.A. Mundkur Fire And Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training Centre Hubballi.

This "Fire Safety Compliance Report" is valid for only one year from the date of issue.

Yours Faithfully.

[Signature]
 District Fire Officer
 Karnataka State Fire And Emergency Services
 Belagavi-01.
 21/7/20

Copy to,
 Fire Station Officer, Hattaragi.